



HAZARDS

- ◆ Fall from height
- ◆ Struck by dropped object
- ◆ Suspension trauma

CONTROLS

- Are all personnel required to use fall protection competent in its use?

- Can the work be performed from a work platform with a protected edge or lowered to the ground to eliminate the requirement for the use of fall protection?

- Have all below work areas been barricaded and signed to warn of work being performed?

- Are all portable ladders tagged to ensure they are approved for site use?

- Is all fall protection equipment inspected, tagged and approved for site use?

- Are all anchor points clearly signed and approved for fall protection equipment attachment?

- Do all scaffolds clearly display the required tagging to indicate approved access?

- Are all scaffolds erected and dismantled by competent and authorised personnel?

- Are all personnel involved in the erection or dismantling of scaffolding wearing and attaching approved fall protection equipment?

- Do all scaffolds display the required tagging to indicate authorised access only during erection, repair, modification or dismantling?

- Is a Permit in place for all works performed from a man cage suspended by a crane?

SUPERVISOR

WORKING AT HEIGHTS